Certificate of compliance

Applicant: Huawei Solar Limited

No. 5, 17F, Strand 50, Bonham Strand, Sheung Wan, Hong Kong

Trademark: **FUJI** SOLAR®

Product: Photovoltaic (PV) and battery inverter

Model:
FU-SUN-5K-SG04LP3-EU
FU-SUN-6K-SG04LP3-EU
FU-SUN-8K-SG04LP3-EU
FU-SUN-10K-SG04LP3-EU
FU-SUN-12K-SG04LP3-EU

Inverter for three-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019
Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

4.4 Normal operating range
4.5 Immunity to disturbances
4.6 Active response to frequency deviation
4.7 Power response to voltage variations and voltage changes
4.8 EMC and power quality
4.9 Interface protection
4.10 Connection and starting to generate electrical power
4.11 Ceasing and reduction of active power on set point
4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

DIN V VDE V 0126-1-1:2006 (4.1 Functional safety)
Automatic disconnection device between a generator and the public low-voltage grid

Commission Regulation (EU) 2016/631 of 14 April 2016
Establishing a network code on requirements for grid connection of generators (NC RFG).
Type approval for generation units to use in Type A and Type B plants

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number:	ASUE-ESH-P22010034	**Certification Program:**	NSOP-0032-DEU-ZE-V01
Certificate number:	U22-0169	**Date of issue:**	2022-03-30

Certification body

Thomas Lammel

((**DAkkS**
Deutsche
Akkreditierungsstelle
D-ZE-12024-01-00

Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH

BUREAU VERITAS
Consumer Products Services Germany GmbH

Oehleckerring 40, 22419 Hamburg, Germany
Tel: +49 40 74041-0

cps-hamburg@de.bureauveritas.com
www.bureauveritas.de/cps

Appendix

Extract from test report according to EN 50549-1 **No. ASUE-ESH-P22010034**

Type Approval and declaration of compliance with the requirements of EN 50549-1 and Commission Regulation (EU) 2016/631 of 14 April 2016

Manufacturer / applicant	**Huawei Solar Limited** No. 5, 17F, Strand 50, Bonham Strand, Sheung Wan, Hong Kong

Micro-generator Type	Photovoltaic and battery inverter			
	FU-SUN-5K-SG04LP3-EU	FU-SUN-6K-SG04LP3-EU	FU-SUN-8K-SG04LP3-EU	FU-SUN-10K-SG04LP3-EU
MPP DC voltage range [V]	200-650	200-650	200-650	200-650
Input DC voltage range [V]	160-800	160-800	160-800	160-800
Input DC current [A]	13+13	13+13	13+13	26+13
Output AC voltage [V]	3L/N/PE 400, 50Hz/60Hz	3L/N/PE 400, 50Hz/60Hz	3L/N/PE 400, 50Hz/60Hz	3L/N/PE 400, 50Hz/60Hz
Output AC current [A]	7,6	9,1	12,1	15,2
Output power [W]	5000	6000	8000	10000
Battery DC voltage range [V]	40-60	40-60	40-60	40-60
Battery charge current [A]	120	150	190	210
Battery discharge current [A]	120	150	190	210

	FU-SUN-12K-SG04LP3-EU	--	--	--
MPP DC voltage range [V]	200-650	--	--	--
Input DC voltage range [V]	160-800	--	--	--
Input DC current [A]	26+13	--	--	--
Output AC voltage [V]	3L/N/PE 400, 50Hz/60Hz	--	--	--
Output AC current [A]	18,2	--	--	--
Output power [W]	12000	--	--	--
Battery DC voltage range [V]	40-60	--	--	--
Battery charge current [A]	240	--	--	--
Battery discharge current [A]	240	--	--	--

Firmware version	Beginning with V1090

Description of the structure of the power generation unit:

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on the inverter bridge and two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.

Note:

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019 Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.