

Certificate of compliance

Huawei Solar Limited Applicant:

No. 5, 17F, Strand 50, Bonham Strand, Sheung Wan, Hong Kong

Trademark:

Product: Photovoltaic (PV) and battery inverter

FU-SUN-50K-SG01HP3-EU-BM4, FU-SUN-40K-SG01HP3-EU-BM4. Model:

FU-SUN-35K-SG01HP3-EU-BM3, FU-SUN-30K-SG01HP3-EU-BM3,

FU-SUN-29.9K-SG01HP3-EU-BM3

Inverter for three-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network -Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection

Certificate number:

- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

DIN VDE V 0124-100:2020 (5.5.2.1 Functional safety of network and system protection)

Grid integration of generator plants - Low-voltage - Test requirements for generator units to be connected to and operated in parallel with low-voltage distribution networks

Commission Regulation (EU) 2016/631 of 14 April 2016

U23-0129 1

Establishing a network code on requirements for grid connection of generators (NC RFG).

Type approval for generation units to use in Type A and Type B plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: ASUE-ESH-P22110228

Certification Program:

NSOP-0032-DEU-ZE-V01

Date of issue:

2023-02-28

Certification body

Alf Assenkamp



Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065 Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH



Annex to the EN 50549-1 certificate of compliance No. U23-0129_1

Appendix				
Extract from test report according to EN 50549-1 No. ASUE-ESH-P2211022				
Type Approval and declaration 2016/631 of 14 April 2016	on of compliance with the	e requirements of EN 5	0549-1 and Commission	n Regulation (EU)
Manufacturer / applicant	Huawei Solar Limited			
	No. 5, 17F, Strand 50, Bonham Strand, Sheung Wan,			
	Hong Kong			
Micro-generator Type	Photovoltaic and battery inverter			
	FU-SUN-50K- SG01HP3-EU-BM4	FU-SUN-40K- SG01HP3-EU-BM4	FU-SUN-35K- SG01HP3-EU-BM3	FU-SUN-30K- SG01HP3-EU-BM3
MPP DC voltage range [V]	150-850			
Max. DC voltage [V]	1000			
Max. PV current [A]	4*36 3*36			
Output AC voltage [V]	3L/N/PE, 230/400, 50 Hz			
Rated AC current [A]	72,5	58,0	50,8	43,5
Max AC current [A]	79,8	63,8	55,8	47,9
Active Power [W]	50000	40000	35000	30000
Apparent power [VA]	55000	44000	38500	33000
Battery voltage [V]	160-800			
Max.Charging/Discharging Current [A]	50+50			
	FU-SUN-29.9K- SG01HP3-EU-BM3			
MPP DC voltage range [V]	150-850 Vd.c.			
Input DC voltage range [V]	1000			
Input DC current [A]	3*36			
Output AC voltage [V]	3L/N/PE, 230/400, 50 Hz			
Rated AC current [A]	43,4			
Max AC current [A]	43,4			
Active Power [W]	29900			
Apparent power [VA]	29900			
Battery voltage [V]	160-800			
Max.Charging/Discharging Current [A]	50+50			
Firmware version	1020			
I IIIIWale velsion	1020			

Description of the structure of the power generation unit:

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on the inverter bridge and two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.



Annex to the EN 50549-1 certificate of compliance No. U23-0129_1

Appendix

Extract from test report according to EN 50549-1

No. ASUE-ESH-P22110228

Note

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019 Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.