

C E R T I F I C A T E

of Conformity



Registration No.: AK 60140318 0001

Report No.: 28113141 006

Holder: Fronius International GmbH
Guenter Fronius-Str. 1
4600 Wels - Thalheim
Austria

Product: Electrical Equipment
Photovoltaic Grid tied inverter

Identification: Model: FRONIUS SYMO 3.0-3-M ; FRONIUS SYMO 3.7-3-M
FRONIUS SYMO 4.5-3-M ; FRONIUS SYMO 5.0-3-M
FRONIUS SYMO 5.5-3-M ; FRONIUS SYMO 6.0-3-M
FRONIUS SYMO 6.7-3-M ; FRONIUS SYMO 7.0-3-M
FRONIUS SYMO 8.0-3-M ; FRONIUS SYMO 8.2-3-M
Compliant to:
- requirements for Type A and Type B Generation Units
- COMMISSION REGULATION (EU) 2016/631 (RfG)
- EN 50549-1:2019

Tested acc. to: EN 50549-1:2019

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date 19.06.2019

Certification Body

Marco Piva



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg